

### **LIFE SAFETY AND FIREFIGHTERS SERVICE ON ELEVATORS**

Elevators shall be subject to routine and periodic tests as specified in ASME/ANSI A17.1, the manufacturer's instructions, and NFPA 101 (latest edition). The following list represents minimum requirements for the safe operation of elevators during a fire. A more complete list is found in ASME/ANSI A17.1, however, this list is not meant to replace manufacturer's instructions. This data is based on the 2010 edition of ASME A17.1 and the 2012 edition of NFPA 101.

#### **Summary of Elevator Firefighters Service Systems Inspection, Testing, and Maintenance**

<b>ITEM</b>	<b>FREQUENCY</b>	<b>REFERENCE</b>
<u>Testing</u>		
Phase I recall and a minimum of 1 floor operation of Phase II	Monthly	A17.1:8.6.11.1
Emergency lighting in the elevator car	Monthly	A17.1:2.14.7.1.3 101:7.9.3

(Elevator power shunt by heat detectors are to be tested in accordance with the interfaced equipment per NFPA 72.)