

## KITCHEN VENTILATION HOODS AND FIRE SUPPRESSION SYSTEMS

Inspection, testing, and maintenance of kitchen ventilation hoods and fire suppression systems shall be performed in accordance with the manufacturer's instructions, NFPA 17 (latest edition), 17A (latest edition), 72 (latest edition), and NFPA 96 (latest edition). Regular service contracts with the equipment manufacturer or an authorized installation or maintenance company are required. The following list highlights minimum requirements for the essential care of kitchen ventilation hoods and fire suppression systems. This list, however, is not meant to replace manufacturer's instructions and updated code requirements. This data is based on the 2013 edition of NFPA 17, the 2013 edition of NFPA 17A, the 2013 edition of NFPA 72, and the 2014 edition of NFPA 96.

Monthly and annual maintenance tags shall be attached to each fire suppression system for recording the inspector's initials, date, and confirmation on maintenance/inspections performed. Where fusible links are used, the manufacturer and the installation dates for the links shall be marked on the system inspection tag. In addition, a signed and dated log of maintenance and a certificate showing date of exhaust system inspection or cleaning shall be available in the food service manager's office and the facility manager's office.

### Summary of Kitchen Ventilation Hoods and Fire Suppression Systems Inspection, Testing, and Maintenance

| ITEM   | FREQUENCY | REFERENCE                |
|--|-----------|--------------------------|
| <u>Inspection</u>  |           |                          |
| Extinguishing system nozzles are located directly above grease producing equipment | Monthly   | 17A:7.2.2<br>17:11.2.1.1 |
| The manual actuators are unobstructed  | Monthly   | 17A:7.2.2<br>17:11.2.1.1 |
| The tamper indicators and seals are intact   | Monthly   | 17A:7.2.2<br>17:11.2.1.1 |
| The maintenance tag or certificate is in place                                     | Monthly   | 17A:7.2.2<br>17:11.2.1.1 |
| No obvious physical damage or condition exists that might prevent operation        | Monthly   | 17A:7.2.2<br>17:11.2.1.1 |
| The pressure gauge(s) are in operable range  | Monthly   | 17A:7.2.2<br>17:11.2.1.1 |
| The nozzle blow-off caps are intact and undamaged                                  | Monthly   | 17A:7.2.2<br>17:11.2.1.1 |
| Neither protected equipment nor hazard has been replaced, modified, or relocated   | Monthly   | 17A:7.2.2<br>17:11.2.1.1 |

**Summary of Kitchen Ventilation Hoods and Fire Suppression Systems  
Inspection, Testing, and Maintenance**

| <b>ITEM</b>  | <b>FREQUENCY</b>                              | <b>REFERENCE</b>           |
|--|---|----------------------------|
| <b>Testing</b>   |   |                            |
| Gas and electric power shutoff are operational   | Semiannually                                  | 17:11.3.1.4                |
| Water-wash hood cleaning systems are operational in conjunction with hoods protected by sprinkler systems                                  | Semiannually                                  | 96:11.2.1                  |
| Recirculating systems operation and safety interlocks perform in accordance with manufacturer's instructions                               | Semiannually, or more frequently if necessary | 96:13.6.5                  |
| Manual release stations are operational and send a signal to the building fire alarm control panel   | Semiannually                                  | 17:11.3.1.4<br>17A:7.3.3.1 |
| Automatic release devices are operational and send a signal to the building fire alarm control panel                                       | Semiannually                                  | 17:11.3.1.4<br>17A:7.3.3.4 |
| Water flow, valve tamper, and low water pressure cutoffs are operational   | Semiannually                                  | 72:T7.3.2                  |
| Verify that the agent distribution piping is not obstructed  | Semiannually                                  | 17:11.3.1<br>17A:7.3.3.1   |
| Hydrostatic pressure test on wet and dry chemical extinguishing systems (agent containers, auxiliary pressure containers, hose assemblies) | Every 12 years                                | 17:11.5.1<br>17A:7.5.1     |
| <b>Maintenance</b>   |   |                            |
| Remove grease from exhaust systems serving solid fuel cooking operations   | Monthly                                       | 96:11.4                    |
| Remove grease from exhaust systems serving high-volume cooking operations, such as 24-hour cooking, charbroiling, or wok cooking           | Quarterly                                     | 96:11.4                    |
| Remove grease from exhaust systems serving moderate-volume cooking operations  | Semiannually                                  | 96:11.4                    |
| Clean electrostatic precipitators on recirculating systems   | Weekly  | 96:13.6.3                  |

**Summary of Kitchen Ventilation Hoods and Fire Suppression Systems  
Inspection, Testing, and Maintenance**

| <b>ITEM</b>  | <b>FREQUENCY</b> | <b>REFERENCE</b>                    |
|--|------------------|-------------------------------------|
| Clean entire hood plenum and blower section on recirculating systems   | Quarterly        | 96:13.6.4                           |
| Replace fixed temperature sensing elements of the fusible alloy type   | Semiannually     | 17:11.3.2<br>17A:7.3.4<br>96:11.2.4 |
| Clean fixed temperature sensing elements other than the fusible metal alloy type   | Semiannually     | 17:11.3.3<br>17A:7.3.5              |
| Examine detectors, expellant gas containers, agent containers, releasing devices, piping, hose assemblies, nozzles, signals, and all auxiliary equipment | Semiannually     | 17:11.3.1<br>17A:7.3.3.4            |